



Registrazione numero/Registration number:

PED/0497/160/03

CERTIFICATO DI CONFORMITÀ UE

EU CERTIFICATE OF CONFORMITY

Visto il Manuale Qualità/Referring to the Quality Manual
MQ_ED.2018 Rev. 00 del/dated 12/01/2018

si certifica che la Società/we certify that the Company

TECNOCONTROL S.r.l.

Sede legale / Registered office

Via E. Fermi, 98 – 25064 GUSSAGO (BS) – ITALY

Unità operativa di / Place of business

Via Miglioli, 47 – 20090 SEGRATE (MI) – ITALY

ha implementato e mantiene un controllo finale sul prodotto conforme all'Allegato I e alla procedura del Modulo D1, Allegato III della Direttiva 2014/68/UE, allo scopo di produrre e testare
has implemented and maintains a final control on the product in compliance with the Annex I and with the Procedures of Module D1, Annex III of the 2014/68/EU Directive, for manufacturing and testing

ELETTROVALVOLA SERIE VR A RIARMO MANUALE

NORMALMENTE APERTA – NA

NORMALLY OPENED MANUAL RESET SOLENOID VALVE -

VR SERIES - NO

PS_{min} 0 barg; PS_{max} 0,55/2/6 barg; TS_{min} -15 °C; TS_{max} +60 °C; DN 25 ÷ 150
Gruppo Fluido/Fluid Group 1 - Categoria/Category II

Il Fabbricante è autorizzato ad apporre sull'Attrezzatura in pressione di cui sopra, dopo la marcatura CE, il numero di identificazione dell'Organismo Notificato.
The Manufacturer is authorized to provide the above pressure Equipment with the CE marking, followed by the Notified Body identification number.

24/09/2003

Prima emissione
First issue

24/09/2024

Rinnovo
Renewal

Ultima emissione
Latest issue

23/09/2027

Scadenza
Expiry



PRD N° 032B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreement



Carlo Dassi
B. A.
Certification

0497

pag. 1/2

GQ002 REV.00



PRD N° 032B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreement

Registrazione numero/Registration number:

PED/0497/160/03

CERTIFICATO DI CONFORMITÀ UE

EU CERTIFICATE OF CONFORMITY

ELETTROVALVOLA SERIE VR A RIARMO MANUALE NORMALMENTE APERTA – NA

NORMALLY OPENED MANUAL RESET SOLENOID VALVE - VR SERIES - NO

PS_{min} 0 barg; PS_{max} 0,55 barg

Cod.						
VR709	VR500	VR710	VR510	VR711	VR520	VR530
VR540	VR550	VR560	VR570	VR580	VR750	VR739
VR403	VR404	VR405	VR406	VR407	VR408	

PS_{min} 0 barg; PS_{max} 2 barg

Cod.	
VR740	VR741

PS_{min} 0 barg; PS_{max} 6 barg

Cod.						
VR929	VR930	VR932	VR933	VR934	VR935	VR936
VR937	VR938					

24/09/2003Prima emissione
First issue**24/09/2024**Rinnovo
Renewal

Ultima emissione
Latest issue**23/09/2027**Scadenza
Expiry

Carlo Dassi

B. A. Certification

pag. 2/2