

TERMINAL ARCHIVE MANAGEMENT



BRIXIA






CPF
INDUSTRIALE

MADE IN ITALY


Starting from firmware version: 02.03.00, the **BRIXIA X** terminal requires an **SD CARD** with a minimum capacity of **512 MB** (in order to allow an increase in storage capacity), which is housed in the appropriate slot.

If the terminal does not have one, proceed as follows:


- 1 TURN OFF THE TERMINAL.
- 2 OPEN THE RECHARGEABLE BATTERY COMPARTMENT.
- 3 TAKE OUT THE BATTERY.
- 4 LOCATE THE SD CARD SLOT.



- 5 INSERT THE **SD CARD**, SECURING IT CORRECTLY.
- 6 REASSEMBLE THE **BRIXIA X**.
- 7 TURN ON THE **BRIXIA X**.
- 8 If the **SD CARD** has been inserted correctly and is readable and writable, the terminal will indicate its presence with an icon on the display.



If you connect to a **PC** using the **USB** cable supplied (useful both for charging the terminal and for data communication), when the **BRIXIA X** is switched on (while waiting for the Windows drivers to load), the **PC** will recognise the **SD CARD** on board the **BRIXIA X** as an external MEMORY CARD.



SD CARD

The **SD CARD** has four directories:

- 1 DATALOGGER
- 2 FACTORY
- 3 MEASURE
- 4 SYSTEM

- The log. files of any log tests performed are stored in the DATALOGGER folder in CSV format.

The CSV format is one of the easiest ways to display data in tabular form within a simple text file. It is no coincidence that this file format was one of the first to be widely used for data exchange and is still used in many applications today.

To understand how a CSV file is created, we can start with the name of this format. CSV is in fact an acronym that stands for Comma Separated Values: as already mentioned, the CSV file is in fact nothing more than a text file that uses commas/semicolons to separate the data contained in each cell of a table.

For example, let's say you want to display the data in the following table in CSV format:

First name	Surname	Age
Mario	Rossi	20
Luigi	Bianchi	51
Clara	Esposito	18
Gennaro	Fumagalli	35

By separating the data contained in each row with a simple semicolon, we obtain the following equivalent CSV file:

```
Nome;Cognome;Età
Mario;Rossi;20
Luigi;Bianchi;51
Clara;Esposito;18
Gennaro;Fumagalli;35
```

- The FACTORY folder contains the terminal configuration (CONFIG) and terminal calibration (CALIB) backup files in dbk. archive format (not readable in text format).

- The MEASURE folder contains the files relating to the individual measurements taken, in TXT format.

e.g. Cliente1_17 Nov 23.txt
 Cliente2_17 Nov 23.txt
 Cliente3_17 Nov 23.txt
 ecc..

One example of the content of the TXT file of a measurement is as follows:

```
BRIXIA X
CPF INDUSTRIALE SRL
S.N.:ST00000009
Fw:02.03.00
```

```
Date Report:
17 Nov 23
15:02
```

```
-----
Maintenance Company:
GECA Srl
Via E.Fermi, 98
25064
Gussago (BS)
03124320171
```

```
---
Operator:
Castiglia
Pasquale
89
```

```
-----
Customer:
Cliente
Via Sede Cliente
24128
BERGAMO
P.IVA Cliente
```

```
Fire Extinguisher:
Progr.: 2
S.N.: A12345-2821
Foam
```

```
Pressure Test
14.03 Bar
```

As far as the product measurement file is concerned, the following is the content and interpretation of the saved data:

1	A	B	C	D	E	F	G	H	I	J	K	L	
1	GECA Srl	Via E. Fermi, 98	25064	Gussago (BS)	03124320171	---	CLIENTE1	PIVA 001	Via CLIENTE1	24124	BERGAMO	Castiglia	
2	GECA Srl	Via E. Fermi, 98	25064	Gussago (BS)	03124320171	---	CLIENTE1	PIVA 001	Via CLIENTE1	24124	BERGAMO	Castiglia	
3	GECA Srl	Via E. Fermi, 98	25064	Gussago (BS)	03124320171	---	CLIENTE2	PIVA 002	Via CLIENTE2	24128	BERGAMO	Castiglia	
4	GECA Srl	Via E. Fermi, 98	25064	Gussago (BS)	03124320171	---	CLIENTE2	PIVA 002	Via CLIENTE2	24128	BERGAMO	Castiglia	
5	AZIENDA MANUTENTRICE												
7	RAG. SOCIALE	INDIRIZZO	CAP	CITTA'	C.FISCALIS / P.IVA	NOTE	CLIENTE	RAG. SOCIALE	P.IVA	INDIRIZZO	CAP	CITTA'	NOTE
8													OPERATORE
9													COGNOME

Data relating to the maintenance company.

Customer data.

1	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z	AA	AB
1	Castiglia	Patquale 89	Water	224	A12345-2242	3-2220	2225	3242	Bar	C	OK	22.30C	17 Nov 23	15 07		
2	Castiglia	Patquale 89	Water	225	A12345-2243	3-2221	2226	3243	Bar	C	OK	22.33C	17 Nov 23	15 07		
3	Castiglia	Patquale 89	Foam	1	A12345-2820	2-2025	2027	3820	Bar	C	22.81	22.19C	17 Nov 23	15 02		
4	Castiglia	Patquale 89	Foam	2	A12345-2821	2-2026	2028	3821	Bar	C	22.83	22.23C	17 Nov 23	15 02		
7	NOTE															
8	OPERATORE															
9	COGNOME	NOME	CODICE	ESTINTORE	PROGRESSIVO	NUMERO SERIE	SCAD. COLLAUDO	SCAD. REVISIONE	SCAD. OMOLOGAZIONE	MISURA RILEVATA						
10				TIPO						UOM PRESS.	UOM TEMP.	MIS. PRESS.	MIS. TEMP.	DATA	ORA	

Operator data.

Fire extinguisher data.

Data relating to the measurement taken.


N.B.
a maximum of 300 measurements can be saved (this limit is imposed by the terminal's FLASH memory), and these measurements can be saved and kept on the **SD CARD** until it is full.

Saving the measurements on the **SD CARD** deletes them from the terminal's internal FLASH, freeing up space.

- The **SYSTEM** folder contains the archives and any backups of the terminal archives. Both the archives and their backups are written in CSV format.

The archives in the **SD CARD** memory are as follows:


factory_azienda.csv contains data about the maintenance company
 see example:



The `factory_azienda.csv` file can contain an unlimited number of records. The terminal will only read the first record in the list and use it for the subsequent operating phases.

`operators_operatori.csv` contains data about the operators in service at the maintenance company.


see example:



The `operators_operatori.csv` file can contain an unlimited number of records, but the terminal will only read and use the first 20 records in the list for the subsequent operating phases.

`customers_clienti.csv` contains customer data.

see example:



The `customers_clienti.csv` file can contain an unlimited number of records, but the terminal will only read and use the first **200 records** in the list for the subsequent operating phases.

fire_extinguishers_estintori.csv

contains data about the fire extinguishers of ALL CUSTOMERS

STOMERS

see example:

A	B	C	D	E	F	G
ESTINTORI Codice Fiscale / PIVA CLIENTE 20 CARATTERI ALFANUMERICI	ESTINTORI Tipo Estintore Tipi consentiti: Powder / Polvere CO2 / CO2 Water / Idrico Other / Altro 20 CARATTERI ALFANUMERICI	ESTINTORI Progressivo ad uso Azienda Manutentrice 10 CARATTERI ALFANUMERICI	ESTINTORI Numero di Serie 20 CARATTERI ALFANUMERICI	ESTINTORI Scadenza Collaudo 10 CARATTERI ALFANUMERICI Non Richiesto	ESTINTORI Scadenza Revisione 10 CARATTERI ALFANUMERICI Non Richiesto	ESTINTORI Scadenza Omologazione 10 CARATTERI ALFANUMERICI Non Richiesto
	CO2		A12345-2000	6-2025	2007	3000
	CO2		A12345-2009	6-2024		2029
	CO2		A12345-2010	6-2024		2029
	CO2		A12345-2011	6-2024		2028
	CO2		A12345-2012	6-2024		2028
	CO2		A12345-2013	6-2024		2028
	CO2		A12345-2014	6-2024		2028
	Dry Powder		A12345-2015	6-2024		2028
	Dry Powder		A12345-2016	6-2024		2028
	Dry Powder		A12345-2017	6-2024		2028
	Dry Powder		A12345-2018	6-2024		2028
	CO2		A12345-2019	6-2024		2028
	CO2		A12345-2020	6-2024		2028
	CO2		A12345-2021	6-2024		2028
	CO2		A12345-2022	6-2024		2028
	CO2		A12345-2023	6-2024		2028
	CO2		A12345-2024	6-2024		2028
	Foam		A12345-2025	6-2024		2028
	Foam		A12345-2026	6-2024		2028
	Foam		A12345-2027	6-2024		2028
	Foam		A12345-2028	6-2024		2028
	CO2		A12345-2029	6-2024		2028
	CO2		A12345-2030	6-2024		2028
	CO2		A12345-2031	6-2024		2028
	CO2		A12345-2032	6-2024		2028
	Water		A12345-2033	6-2024		2028
	Water		A12345-2034	6-2024		2028
	Water		A12345-2035	6-2024		2028
	Water		A12345-2036	6-2024		2028
	Water		A12345-2037	6-2024		2028
	Water		A12345-2038	6-2024		2028
	Water		A12345-2039	6-2024		2028
	CO2		A12345-2040	6-2024		2028
	CO2		A12345-2041	6-2024		2028

The file fire_extinguishers_estintori.csv, can contain an indefinite number of records, but the terminal will only read and use the first 300 records that appear in the fire extinguisher list for the selected customer for the subsequent operating phases.

To be able to insert the records in the listed archives it is necessary to operate as described:

- 1 – CONNECT THE SUPPLIED **USB** CABLE TO THE PC AND THE TERMINAL
- 2 – TURN ON THE TERMINAL
- 3 – WAIT FOR THE PC TO RECOGNIZE THE **SD CARD** CONTAINED IN THE **BRIXIA X** TERMINAL

At this point the **PC** will show the contents of the **SD CARD**

Navigate to the file you wish to process and proceed by opening it:

OPEN WITH → e.g. LIBRE OFFICE

Libre Office will recognise the CSV format of the file and display the following screen asking you how to proceed.

Importa

Tipo di carattere: Unicode (UTF-8) ▾

Lingua: Predefinita - Italiano (Italia) ▾

Dalla riga: 1 ▾

Opzioni di separazione

- Larghezza fissa Separato da
- Tabulazione Virgola Punto e virgola Spazio Altro
- Raggruppa i separatori di campo Ritaglia spazi Delimitatore di stringa: ' ▾

Altre opzioni

- Formatta il campo tra virgolette come testo Individua numeri speciali
- Valuta formule

Campi

Tipo colonna: ▾

	Standard	Standard	Standard	Standard	Standard	Standard
1	GECA SRL	Via E.Fermi, 98	25064	Gussago (BS)	03124320171	---

AiutoOKAnnulla

- 1 • Select all fields identified:

Importazione testo - [factory_azienda.csv]

Importa

Tipo di carattere: Unicode (UTF-8)

Lingua: Predefinita - Italiano (Italia)

Dalla riga: 1

Opzioni di separazione

Larghezza fissa Separato da

Tabulazione Virgola Punto e virgola Spazio Altro

Raggruppa i separatori di campo Ritaglia spazi Delimitatore di stringa: ' ' ▾

Altre opzioni

Formatta il campo tra virgolette come testo Individua numeri speciali

Valuta formule

Campi

Tipo colonna: Standard ▾

	Standard	Standard	Standard	Standard	Standard	Standard
1	GECA SRL	Via E.Fermi, 98	25064	Gussago (BS)	03124320171	---

Aiuto OK Annulla

- 2 • Select TEXT as the 'Column Type'.

Importazione testo - [factory_azienda.csv]

Importa

Tipo di carattere: Unicode (UTF-8) ▼

Lingua: Predefinita - Italiano (Italia) ▼

Dalla riga: 1 ▼

Opzioni di separazione

Larghezza fissa Separato da

Tabulazione Virgola Punto e virgola Spazio Altro

Raggruppa i separatori di campo Ritaglia spazi Delimitatore di stringa: ' ▼

Altre opzioni

Formatta il campo tra virgolette come testo Individua numeri speciali

Valuta formule

Campi

Tipo colonna: Testo ▼


	Testo	Testo	Testo	Testo	Testo	Testo
1	GECA Srl	Via E.Fermi, 98	25064	Gussago (BS)	03124320171	---

Aiuto OK Annulla

The import is finished.

3 • Proceed with data entry.

At the end of the job, when prompted to save the **added/modified** data, the program will propose the following choice:




Pick **Use CSV Text format**.



Please read this instruction manual carefully and keep it together with the other documents that come with this product.

All documentation relating to the product must be retained as it contains the procedures to be followed for periodic maintenance and servicing.



AC993 BRIXIA X is the pressure tester for fire extinguisher inspections designed in response to modern pressure test requirements for pressurised powder extinguishers. The tester comes complete with a rugged IP67 waterproof case containing everything you need to perform pressure tests, including a Bluetooth printer and calibration report. You can use the QR code to send measurement data directly to the appropriate management software. This instrument meets the requirements of UNI 9994-1:2013 Section 4.5

 All parameters preset in the tester are based on Italian (UNI) and European (EN) standards. If the tester is used abroad or for different standards, the test parameters can be changed within the limits set for each type of test.
For any clarifications, please contact **CPF Industriale**.



PRESSURE TESTS MUST ONLY BE CARRIED OUT BY QUALIFIED AND AUTHORISED PERSONNEL IN ACCORDANCE WITH THE REQUIREMENTS OF THE APPLICABLE STANDARDS. THE OPERATOR IS RESPONSIBLE FOR UNDERSTANDING AND CORRECTLY APPLYING THE STANDARDS. DEPENDING ON THE TEST SELECTED, THE FORMULAE AND CALCULATIONS PERFORMED BY THE TESTER COMPLY WITH THE RELEVANT STANDARDS UP TO THE DATE OF MANUFACTURE. THE ADDITION OF FURTHER TESTS OR ANY UPDATES TO STANDARDS OR OTHER FEATURES OF THE TESTER WILL BE SUBJECT TO A FIRMWARE UPDATE.



		INSTRUCTION LEAFLET
		PAPER COLLECTION
		Check the regulations of your municipality

Directive 2012/19/UE (Waste Electrical and Electronic Equipment - WEEE):



Information for users:

The crossed out wheeled bin label that can be found on your product indicates that this product should not be disposed of via the normal household waste stream. To prevent possible harm to the environment or human health please separate this product from other waste streams to ensure that it can be recycled in an environmentally sound manner.

For more details on available collection facilities please contact your local government office or the retailer where you purchased this product.

WEEE



CPF
INDUSTRIALE

CPF Industriale
via E.Fermi, 98 - 25064
Gussago (BS), Italy
Tel. +39 030 310461

cpfgroup.it

The manufacturer reserves the right to make any aesthetic or functional change without notice and at any time.